



micro air inc.

6320 La Pas Trail, Indianapolis, IN 46268 * Phone: (317) 293-1533 * lab@microair.com * www.microair.com

May 6, 2025

Carmel Clay Parks & Recreation
1411 E. 116th St.
Carmel, IN 46032

Coliform in Drinking Water Sample Results

Project Name: Flowing Well
Project Number: PWS # IN2290801

Location: Flowing Well - 5100 E. 116th St.
Date Received: May 5, 2025

Enclosed please find the results of samples analyzed by the Micro Air, Inc. laboratory.

Samples were analyzed according to EPA Approved Colilert Presence/Absence Procedure. Micro Air, Inc.'s laboratory is in compliance with the quality assurance as specified by the method and is accredited by the Indiana State Department of Health for the bacteriological examination of public waters (M-49-5).

This report may not be reproduced, except in full, without written approval from Micro Air, Inc. These results only relate to the items tested and are only as accurate as the sampling information submitted by the customer (e.g. air volumes). Samples are received in good condition unless otherwise noted.

Analyzed By:
Megan E. Harris

Authorized By:

Betsie L. McAfee
Technical Manager

Client: Carmel Clay Parks & Recreation
Report Date: 5/6/2025
Lab Number: 198134

Project Number: PWS # IN2290801
Project Name: Flowing Well

Coliform in Drinking Water Sample Results

Location: Flowing Well - 5100 E. 116th St.

Sample ID	Client Sample ID	Date Collected	Date Analyzed	Sample Description	Total Coliforms	E.coli	Result Status
001	FW	5/5/2025	5/6/2025	Flowing Well	Absent	Absent	Satisfactory

Megan Harris has reviewed this final report.

Interpretation: Results are reported as either present or absent for both total coliforms and E. coli. If both results are reported as absent, your sample is satisfactory. If either total coliform or E. coli results are present, your sample is unsatisfactory.